

沙田 302 管理有限公司

S.T. 302 Management Limited

地址：新界沙田安景街 19 至 21 號地下

電話：2646 1859 傳真：2637 6131

本公司檔號：ST302/NTT/278/19/CH

致：金蘭閣各業戶

通 告 有關金蘭閣污水渠淤塞事宜

茲通知各業戶，於本月 6 日晚上，金蘭閣 1 樓 A 及 H 單位有污水由洗手間倒流入屋，本處技工及清潔部主管等即時趕回屋苑了解及處理。經檢查後，發現是 A 及 H 雙連主污水渠淤塞，導致污水倒流，並由技工進行通渠後已將污水停止倒流及回復暢通。最後，本處清潔職員為受影響業戶單位進行清洗工作。

管理處現呼籲各業戶，為本身及其他住戶利益著想，切勿將任何雜物掉進坐廁內，並提醒裝修人士切勿將裝修廢料掉進污水渠內防止污水渠淤塞。多謝合作。

如有查詢，請於辦公時間內致電 2646 1859 與本處職員聯絡。

不便之處，敬請原諒！

碧濤花園第一期管理處
2019 年 11 月 7 日

Date: 7 November, 2019

To: All Residents of Capilano Court

NOTICE Blockage of Sewage Pipe at Capilano Court

Please be informed that there had sewage spilling out from washroom in units A and H on the 1st floor of Capilano Court at night on 6 November 2019. Our technicians and cleaners etc. immediately came back estate to investigate and handle the case.

After checking, it was found that there was blockage of the main-sewage pipe for units A and H causing sewage backflow. The sewage blackflow was stopped and resumed normal after our technician cleaned up the main-sewage pipe. Finally, our cleaning contractor cleaned all affected units.

Please be advised that all residents and decorators should never drop any articles, debris and renovation waste into toilets to prevent blockage of sewage pipe. Thanks for your cooperation.

For any enquiries, please contact our staff at 2646 1859 during office hours.

We apologize for any inconvenience caused.

Management Office of Pictorial Garden Phase I



通告張貼日期至 2019 年 11 月 29 日
Notice will posted until 29 November, 2019